

# EXHIBIT 6

## City of Jackson- PWS 0250008

Highlighted Sites, Action Level for Lead Exceeded

Sample Results During Compliance Period Ending 12/31/2015										Preliminary Sample Results Collected January 2016			
LAB ID#	DATE COLLECTED	PB RESULT	UOM	Block	Street	ACTION LEVEL	site #	location	time	Sample Date	Report Date	PB Result	Comments
150625-077PB	6/23/2015	0.0171	PPM	2000		0.015	249	kitchen	no time/date	1/29/2016	1/30/2016	0.016	
150625-109PB	6/23/2015	0.0192	PPM	1100			135	kitchen	7:45 AM	1/29/2016	1/30/2016	0.012	
150625-111PB	6/23/2015	0.0197	PPM	5400			27	kitchen	not legible	1/29/2016	1/30/2016		Non-responsive
150625-112PB	6/23/2015	0.0216	PPM	4300			76	bathroom	5 00 AM	1/29/2016	1/30/2016	<0.005	Not detected
150625-072PB	6/24/2015	0.0242	PPM	5600			83	kitchen	7:44	1/29/2016	1/30/2016		Vacant
150625-087PB	6/23/2015	0.0254	PPM	5900			187	kitchen	8 00 AM	1/29/2016	1/30/2016	0.016	
150625-115PB	6/22/2015	0.0264	PPM	5000			22	bathroom	10 00 AM	1/29/2016	1/30/2016	<0.005	Not detected
150625-117PB	6/23/2015	0.0362	PPM	4400			69	powder room	10:14 AM	1/29/2016	1/30/2016	<0.005	Not detected
150625-125PB	6/22/2015	0.0385	PPM	400			75	kitchen	9:44 PM	1/29/2016	1/30/2016	0.009	
150625-127PB	6/23/2015	0.0793	PPM	4300			81	kitchen	6 05 AM	1/29/2016	1/30/2016	<0.005	Not detected
150625-119PB	6/22/2015	0.096	PPM	1700			29	bath tub	6:45 PM	1/29/2016	1/30/2016	<0.005	Not detected
150625-124PB	6/23/2015	0.1012	PPM	5000			24	kitchen	4:30 AM	1/29/2016	1/30/2016	0.011	
150625-123PB	6/23/2015	0.1284	PPM	5000			25	kitchen	7:30 AM	1/29/2016	1/30/2016	<0.005	Not detected
150625-083PB	6/23/2015	0.0006	PPM	170									
150625-089PB	6/23/2015	0.0007	PPM	70									
150625-100PB	6/23/2015	0.0007	PPM	30									
150625-075PB	6/21/2015	0.0008	PPM	150									
150625-105PB	6/23/2015	0.0009	PPM	200									
150625-122PB	6/23/2015	0.001	PPM	430									
150625-085PB	6/23/2015	0.0011	PPM	600									
150625-092PB	6/23/2015	0.0013	PPM	30									
150625-076PB	6/23/2015	0.0014	PPM	520									
150625-073PB	6/24/2015	0.0014	PPM	140									
150625-099PB	6/23/2015	0.0015	PPM	70									
150625-126PB	6/23/2015	0.0015	PPM	430									
150625-103PB	6/23/2015	0.0016	PPM	280									
150625-070PB	6/23/2015	0.0017	PPM	510									
150625-081PB	6/23/2015	0.0017	PPM	50									
150625-082PB	6/23/2015	0.0019	PPM	140									
150625-095PB	6/23/2015	0.0021	PPM	310									
150625-101PB	6/23/2015	0.0022	PPM	320									
150625-104PB	6/23/2015	0.0023	PPM	280									
150625-080PB	6/23/2015	0.0028	PPM	40									
150625-120PB	6/23/2015	0.0034	PPM	470									
150625-071PB	6/23/2015	0.0036	PPM	60									
150625-078PB	6/23/2015	0.0036	PPM	170									
150625-084PB	6/23/2015	0.0041	PPM	300									
150625-090PB	6/23/2015	0.0041	PPM	610									
150625-121PB	6/23/2015	0.0047	PPM	500									
150625-116PB	6/22/2015	0.0055	PPM	500									
150625-086PB	6/23/2015	0.0056	PPM	160									
150625-074PB	6/23/2015	0.0059	PPM	220									
150625-113PB	6/23/2015	0.0072	PPM	540									
150625-118PB	6/22/2015	0.0088	PPM	500									
150625-098PB	6/23/2015	0.0096	PPM	600									
150625-094PB	6/23/2015	0.0097	PPM	590									
150625-114PB	6/23/2015	0.0099	PPM	170									
150625-110PB	6/23/2015	0.0104	PPM	430									
150625-096PB	6/23/2015	0.0108	PPM	290									
150625-079PB	6/24/2015	0.0111	PPM	600									

150625-102PB	6/23/2015	0 0128	PPM	20									
150625-091PB	6/23/2015	0 0132	PPM	590									
150625-093PB	6/22/2015	ND		60									
150625-097PB	6/23/2015	ND		540									
150625-107PB	6/23/2015	ND		30									
150625-106PB	6/23/2015	ND		30									
150625-088PB	6/23/2015	ND		50									
150625-108PB	6/23/2015	ND		130									